

NOTE:
ADD INSULATION AS PER SPECIFICATION IF GOOSENECK HAS INSUFFICIENT COVER.

GALVANIZED SERVICE BOX c/w STAINLESS STEEL ROD. (TOP EXTENSION TO SLIDE FREELY. REMOVE ADJUSTMENT BOLT FROM EXTENSION.)


50mm STOP AND DRAIN VALVE c/w BOX AND RISER (SEE DETAIL ABOVE)

ADAPT TO 50mm M.I.P. NIPPLE c/w GALV. CAP
15"x20"(MIN.)x12" HIGH RECTANGULAR PLASTIC IRRIGATION METER BOX (DURA 15"x21", CARSON 1220-3, RAIN-BIRD STD, OR APPROVED EQUAL. LID MARKING TO READ "WATER" OR BLANK) c/w LOCKING LID PENTA BOLT. LOCATE RISER NEAR END OF BOX.

NOTE

1. IN HIGH GROUND WATER CONDITIONS OR AT THE REQUEST OF E.U. AN APPROVED PROTECTIVE TAPE OR WRAP MAYBE REQUIRED TO PROVIDE CORROSION PROTECTION ON ALL METAL FITTINGS. - PG 105 SECTION 11 3.3.7

6	15	06	10	ADDED NOTE AND BURY DEPTH	JED	DATE:	09/01/29
5	12	05	23	GENERAL REVISION	CCK GK	SCALE:	1:30
4	11	07	21	GENERAL REVISION	CRB GK	DRAWN:	C.G.K.
3	11	01	24	GENERAL REVISION	CCK GK	APPROVED:	SANDRA PLANK
2	10	12	29	REVISED AS PER MARK UP	PMD GK		
1	09	04	21	ADDED CS BED, REVISED IRRIG. BOX	CCK GK		
No.	YY	MM	DD	REVISION DESCRIPTION	BY	APP'D	


Medicine Hat
 The Gas City
 Environmental Utilities

MANUAL AIR RELEASE
 DWG. No. **EU-219**