



- NOTES:
1. SAND LAST 25mm OF COPPER PIPE TO REMOVE ROUGHNESS AND CORROSION PRIOR TO APPLYING COUPLER.
 2. SAND 25mm OF PIPE AT GROUND CLAMP LOCATION TO ENSURE GOOD GROUND CONNECTION.

No.	YY	MM	DD	REVISION DESCRIPTION	BY	APP'D	DATE:	12/04/23
							SCALE:	N.T.S.
							DRAWN:	CRB/CGK
							APPROVED:	JBM

Medicine Hat
The Gas City

Environmental Utilities

**WATERMAIN RENEWAL PROJECTS
TIE TO EXISTING COPPER SERVICE
ADDITIONAL GROUNDING DETAIL**

DWG. No. **EU-220**