



NOTES

1. INVERTED KEY TYPE CURB VALVES NOT ACCEPTABLE.
2. SERVICE SADDLE SHALL BE USED FOR CONNECTION OF SERVICE LINE TO WATER MAIN. SERVICE SADDLE SHALL BE ROBAR 2706 OR APPROVED EQUAL.
3. IN HIGH GROUND WATER CONDITIONS AN OR AT THE REQUEST OF E.U. AN APPROVED PROTECTIVE TAPE OR WRAP MAYBE REQUIRED TO PROVIDE CORROSION PROTECTION ON ALL METAL FITTINGS - PG. 105 SECTION 11 3.3.7

SIDE ELEVATION

END VIEW
ELEVATION DETAIL

No.	YY	MM	DD	REVISION DESCRIPTION	BY	APP'D
7	11	06	28	ADDED NOTE & REVISED BURY DEPTH	JED	
7	11	06	28	REVISED NOTES	CRB	GK
7	10	12	17	REVISED NOTES	PMD	GK
6	09	04	20	ADDED CURB STOP BED	CGK	GK
5	07	07	11	ADDED NOTE	CGK	BG
4	06	03	29	CONVERTED TO CAD	CGK	
3	02	03	22	CHANGED DWG NUMBER FROM EU-204B	CGK	
2	01	11	21	DETAIL NOTE, MARKER POST	CGK	
1	01	08	21	CREATED FROM EU-204	CGK	

DATE:	80/08/
SCALE:	N.T.S.
DRAWN:	V.S.
APPROVED:	SIEWAL. MAR.

Medicine Hat
The Gas City

Environmental Utilities

STANDARD PARKS IRRIGATION
SERVICE CONNECTION

DWG. No. EU-207